

6000 PLUS/HT/TSVAD - Heat Sensor Plus Talking Sounder and Visual Alarm Device

- Ideal Where Smoke Detection is Unsuitable
- Integrated Voice Enhanced Sounder
- Integrated EN54-23 Visual Alarm Device
- Seven Selectable Voice Messages
- Loop Powered
- Low Current
- Programmable Volume Control
- Integral Short Circuit Isolator
- Protec Algo-Tec™ 6000*PLUS* Protocol
- Devices Display Address Number
- FAST™ Addressing
- VAD Classification Adjustable from 3m to 7.5m Room Coverage Volume



The Protec Algo-Tec™ 6000*PLUS* sensor range has been developed to incorporate advanced fire sensing technology, electronic sounders, high intensity LED visual alarm devices (VAD) and speech enhanced talking sounder capability, all integrated within the sensor head and powered from the loop.

6000PLUS/HT/TSVAD

Interactive addressable heat sensor with low thermal mass thermistor, giving fast response to temperature increases.

The intelligent sensor data is evaluated by the Protec Algo-Tec TM 6000*PLUS* interactive programmable algorithms.

Suitable for applications where smoke detection is unsuitable but require a high sensitivity heat detector. Examples are boiler rooms, kitchens, laundries and ventilated areas.

Sensor Talking Sounder - For the ultimate method of alerting building occupants of the incidence of an emergency, the Protec Algo-Tec TM 6000 PLUS sensor is equipped with an integrated voice enhanced sounder. The talking sounder

is capable of delivering synchronised alert and evacuate messages around a building, removing any ambiguity, particularly for anyone unfamiliar with the building alert and evacuation strategy, enabling a more prompt and safe building evacuation.

Sensor VAD - Compliance with DDA legislation is assisted by the addition of the Protec visual alarm device (VAD) to the 6000 PLUS ensor, to warn those with hearing impairments or in noisy environments. The VAD utilises a high intensity LED with lower power consumption and increased reliability when compared to alternative indicators.


The VAD is located in the centre of the sensor, so can be viewed from all angles. Suitable for ceiling mounting the VAD distributes light in a cylindrical pattern to achieve the required minimum illumination of 0.4lux over the entire coverage area in accordance with EN54-23.

The maximum mounting height is 3m with a coverage diameter of 7.5m.


For smaller areas the device can be programmed on-site for coverage diameter of 3m or 5m at reduced power.

6000 PLUS/HT/TSVAD Technical Specification

Dimensions (mm)



Typical Wiring using 6000PLUS/BASE



Technical Specification:

Environment -10°C to +50°C (95% R.H. non condensing)

Ingress Protection IP21C

Applicable Standards EN 54-3, 5, 17 & 23, CE Marked

Weight (excluding base) 109.46g Loop Powered Yes

Loop Voltage 18 - 28V
Loop Standby Load 0.55mA
Peak Alarm Load 25mA

Mounting Height 3m

Coverage 7.5m, 5m or 3m cylindrical diameter

VAD Flash Rate 1Hz or 0.5Hz white flash

Isolator Yes

Device Protocol Algo-Tec™ 6000*PLUS*

Design Guidance

Protec VAD's have been approved to BS EN 54-23 and use the rating codes below:

C-x-y (eg C-3-7.5)

Where:

- C is ceiling mounted
- x is the maximum height (M)
- y is the illumination diameter for the cylindrical volume (M)

BS EN 54-23 approved VAD's are approved as ceiling mounted and must provide a minimum illumination level of 0.4 lux for the stated volume

Table A: Direct Viewing

Coverage volumes for various ambient light levels (lux)

C-3-7.5
Ceiling
8.4h x 21dia
7.2h x 18dia
5.7h x 14.3dia
4.2h x 10.5dia
3.3h x 8.3dia
2.7h x 6.8dia
2.1h x 5.3dia
1.5h x 3.8dia


Table B: Indirect Viewing

Coverage volumes for various ambient light levels (lux)

BS EN54-23 Rating	C-3-7.5
Mounting Position	Ceiling
Less than 100 lux	3.9h x 9.8dia
100 - 200 lux	3.6h x 9dia
200 - 300 lux	3.0h x 7.5dia
300 - 400 lux	2.4h x 6dia
400 - 500 lux	1.8h x 4.5dia
500 - 600 lux	1.5h x 3.8dia
600 - 700 lux	*
700 - 800 lux	*

Coverage volumes height, diameter length and width dimensions are in metres.

* Where ambient light levels may, at any time, exceed 600 lux, direct viewing is preferred (CoP 001 clause 4.6.9.4)





Company Policy is one of continuous improvement, we reserve the right to change specification without prior notice

Protec Fire Detection Plc, Protec House, Churchill Way, Nelson, Lancashire, BB9 6RT